

CONCLUSION

The Fulton steam boiler operated during the experiment with a determined thermal efficiency of 13.75% compared to that of standard equal to 40%. More over the equivalent evaporation was also determines as $E_e = 1.73 \text{ Kg/s}$.

REFERENCES

1. YUNUS A. Michael A.B, Thermodynamics, 6th edition (2007), Longman, USA McGraw Hill publishers.
2. JOEL, RAYNER, Engineering Thermodynamics, 4th Edition (1988), Longman, UK.
3. Laboratory Instru~~ct~~